

DRC
SITE PLAN REVIEW AND COMMENT
REPORT

Division: Engineering

Member: Tim Welch
Engineering Design Mgr.
Office Ph. 954-828-5123
Office Fax: 954-828-5275
Email: timw@cityfort.com

Project Name: City of Fort Lauderdale/GT
Lohmeyer WTP

Case #: 3-R-04

Date: January 13, 2004

Comments:

1. Please contact Tim Welch for Engineering comments.

DRC
SITE PLAN REVIEW AND COMMENT
REPORT

Division: Fire

Member: Albert Weber
954-828-5875

Project Name: City of Fort Lauderdale/GT
Lohmeyer WTP

Case #: 3-R-04

Date: January 13, 2004

Comments:

1. How is egress from secured area achieved? Compliance with NFPA 101, 7.2.1.5 required.

DRC
SITE PLAN REVIEW AND COMMENT
REPORT

Division: Info. Systems

Member: Gary Gray
(GRG)
954-828-5762

Project Name: City of Fort Lauderdale/GT
Lohmeyer WTP

Case #: 3-R-04

Date: January 13, 2004

Comments:

1. No apparent interference will result from this plan at this time.

DRC
SITE PLAN REVIEW AND COMMENT
REPORT

Division: Landscape

Member: Dave Gennaro
954-828-5200

Project Name: City of Fort Lauderdale/GT
Lohmeyer WTP

Case #: 3-R-04

Date: January 13, 2004

Comments:

1. Subject to Public Purpose Use approval.

DRC
SITE PLAN REVIEW AND COMMENT
REPORT

Division: Planning

Member: James Cromar
954-828-8958

Project Name: City of Fort Lauderdale/GT
Lohmeyer WTP

Case #: 3-R-04

Date: January 13, 2004

Comments:

1. Provide a narrative outlining compliance with Sec 47-18.26 Public Purpose Uses. Separate the narrative for this application from the other security fence
2. Provide a narrative identifying all sections of the ULDR for which applicant is seeking a waiver.
3. Demonstrate compliance with landscaping requirements for fences (Sec. 47-19.5.C.2).
4. Discuss with staff the option of a vinyl-coated fence and landscaping where fencing is visible from the street.
5. Respond to comments within 90 days or additional DRC review may be required.
6. Additional comments may be forthcoming at DRC meeting.

DRC
SITE PLAN REVIEW AND COMMENT
REPORT

Division:	Police	Member:	Det. Gary J. Gorman 954-828-6421
Project Name:	City of Fort Lauderdale/GT Lohmeyer WTP	Case #:	3-R-04
Date:	January 13, 2004		

Comments:

1. Would it be possible to use a vertical bar fence rather than a chain-link style? Chain link is so easily defeated as well as unsightly when used in this volume. It is difficult to maintain as well.
2. Will this fence/gate be electronically controlled by card access system? If not, how will access to the facility be controlled?
3. All lighting should conform to standards set by the IESNA (Illumination Engineers Society of North America).
4. All gates and locking devices will have sufficient security rating.
5. All landscaping should allow full view of location.
6. **Please submit comments in writing prior to DRC sign-off.**

DRC
SITE PLAN REVIEW AND COMMENT
REPORT

Division: Zoning

Member: Terry Burgess
954-828-5913

Project Name: City of Fort Lauderdale/GT
Lohmeyer WTP

Case #: 3-R-04

Date: January 13, 2004

Comments:

1. Public purpose uses require a site plan level IV review.
2. Barbed wire fencing shall not be permitted pursuant to section 47-19.5.H.
3. Pursuant to section 47-19.5 a minimum average of a three (3) foot setback is required along a public right of way